



NAVAL SUPPORT ACTIVITY BAHRAIN (NSAII) 2019 DRINKING WATER CONSUMER CONFIDENCE REPORT



Is our water safe to drink?

Yes. NSAII Bahrain's drinking water system provides water that is safe and Fit for Human Consumption (potable) as determined by the Installation Commanding Officer's Record of Decision dated 27-Oct-2014 and as routinely confirmed by laboratory sampling results (received monthly, quarterly, and yearly). We are proud to support the Navy's commitment to provide safe and reliable drinking water to our service members and their families. This annual Consumer Confidence Report includes general and mandatory information to educate everyone about our water source(s), treatment processes, standard requirements, and other details to help assure you that our water is safe to drink.

Our drinking water fully complies with the DoD's Final Governing Standards (FGS), which are derived from the U.S. DoD Overseas Environmental Baseline Guidance Document (OEBGD), U.S. Environmental Protection Agency (EPA) and Bahrain drinking water standards. When Bahrain and U.S. standards differ, the *most protective* requirement is adopted into the FGS. A detailed list of constituents found in our drinking water is included in this report, along with a comparison to the maximum levels considered safe for the general public by these standards.

Where does our water come from and how is it treated?

NSAII Bahrain purchases treated water from the Kingdom of Bahrain Electricity & Water Authority (EWA). This water comes from the ocean and is treated at the Al Hidd Water Plant, a multi-stage flash distillation plant. Water received from the City of Manama- Hidd Plant is further treated at NSA II Bahrain facility using 3-stage Reverse Osmosis (RO) units, to render the water potable. Disinfection of the water is achieved by chlorination. This Potable water is stored in secured and controlled access tanks at each facility for direct distribution to various outlets throughout NSA II water distribution network.

Why are there contaminants in drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. NSAII Bahrain drinking water source is distilled; however, distillation is not 100% effective in removing all contaminants because: 1) droplets of un-vaporized liquid can be carried with the steam prior to distillation, and 2) some contaminants have boiling points similar to water and will be vaporized and condensed with the distilled water. In order to ensure that tap water is safe to drink, regulations limit the amount of certain contaminants in water provided by public water systems.

Consequently, some contaminants may be present in drinking water, such as:

- **Microbial contaminants**, such as viruses and bacteria, that may come from wildlife, sewage treatment plants, septic systems, and livestock;
- **Disinfection by-products**, such as chlorine and chloramine used to remove pathogens from the water;

- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses;
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming;
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

The presence of contaminants does not necessarily indicate that water poses a health risk. In order to ensure that tap water is safe to drink, regulations limit the amount of certain contaminants in water provided by public water systems. Regular sampling is conducted to detect the level of contaminants in the water system. If the results are above regulatory limits, you will be notified by Email and Public Notification. You can learn more about contaminants and any potential health effects by visiting the EPA's Drinking Water Standards web site:

<http://permanent.access.gpo.gov/lps21800/www.epa.gov/safewater/standards.html>

Source water assessment

In Jun 2018, the Naval Facilities Engineering Command (NAVFAC) together with the Navy and Marine Corps Public Health Center (NMCPHC) conducted a comprehensive sanitary survey of the NSA Bahrain drinking water system. This survey, conducted every three years, provides an evaluation of the adequacy of the drinking water source, facilities, equipment, operation and maintenance for producing and distributing safe drinking water. NAVFAC is continually improving the drinking water system based on the recommendations in the report.

Some people must use special precautions

There are people who may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the EPA's Safe Drinking Water webpage: www.epa.gov/safewater/sdwa.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NAVFAC EURAFSWA NSA Bahrain Public Works is responsible for providing high-quality drinking water and has direct control over the materials used in plumbing components on the facility. This ensures that no lead service lines or components are used on the drinking water system. As a general safety practice, whenever - and wherever - you plan to use tap water for drinking or cooking, you can minimize the potential for lead exposure by flushing the tap for 30 seconds to 2 minutes prior to use. Information on lead in drinking water and steps you can take to minimize exposure is available from the USEPA Safe Drinking Water website: www.epa.gov/safewater/lead

Water Quality Data Table

The table below lists all of the drinking water contaminants and relevant sampling data collected during the 2019 calendar year. Unless otherwise included, the table below only lists the contaminants that were detected during calendar year 2019. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. All contaminants detected in NSAII Bahrain's drinking water are below the Maximum Contaminant Levels (MCLs) allowed by FGS, DoD, and EPA applicable requirements.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Units	Sample Date	Violation	Typical Source
Inorganic Components							
Sodium	N/A	N/A	13	mg/L	28-Sep-2019	NO	Erosion of natural deposits; Leaching
Magnesium	N/A	N/A	0.52	mg/L	28-Sep-2019	NO	Erosion of natural deposits; Leaching
Silica	N/A	N/A	0.08	mg/L	28-Sep-2019	NO	Erosion of natural deposits; Leaching
Calcium	N/A	N/A	41	mg/L	28-Sep-2019	NO	Erosion of natural deposits; Leaching
Chlorides	N/A	N/A	2.7	mg/L	28-Sep-2019	NO	Erosion of natural deposits; Leaching
Sulfate	250	N/A	0.77	mg/L	28-Sep-2019	NO	Runoff/leaching from natural deposits
Zinc	N/A	N/A	0.14	mg/L	25-Aug -2019	NO	Erosion of natural deposits; Leaching
Nitrates	N/A	10	N/D	mg/L	30-Dec-2019	NO	Byproduct of drinking water disinfection
Total Nitrite and Nitrate	N/A	10	N/D	mg/L	30-Dec-2019	NO	Byproduct of drinking water disinfection
Note: All other Inorganic Compounds, Organic Compounds, Pesticides, PCBs, Total Trihalomethanes and Radionuclides, Lead, Copper and Total Coliforms were not detected							

N/D= Not Detected, i.e below PQL

PQL= Practical Quantitation Limit of the best method

Unit Descriptions	
Term	Definition
mg/L	milligrams per liter ppm: parts per million, or (mg/L)
N/A	Not Applicable
N/D	Not Detected

Important Drinking Water Definitions	
Term	Definition
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Variances and Exemptions: EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Violation(s) or Exceedance(s)/MISSED SAMPLING EVENTS:

There were no violations, exceedances, or missed sampling events during the year 2019 for any tests parameters for NSA II Bahrain.

However, this section also provides the Tier 3 notification requirements in accordance with Navy policy and USEPA procedures. Tier 3 notifications do not have an impact on human health but are required to be reported. When water systems violate a drinking water standard that does not have a direct impact on human health (in this case failing to take a required sample on time) the water supplier has up to a year to provide a notice of this situation to its customers. For NSAI one sampling event was missed in 1st quarter 2019 due to an error with funding for the laboratory, but this was corrected and the sample was analyzed the following quarter with no exceedances.

Points of Contact

If you have any questions regarding this report or about the drinking water processes, please contact:

Patrick Smith
Installation Environmental Program Director
Coordinator, Installation Water Quality Board
Phone: +973-17-85-4603
Email: Patrick.g.smith@me.navy.mil