	A	В	С	D	E	F	G	Н	I	J	L
1	Installation or Command Name	Building Number	Building Name	Room	Location within Rm	Detector ID (reqd)	Detector Type	Manufacturer	Date Placed	Date Retrieved	pCi/L
2	NOSC Little Rock	2	Navy Operational Support Center	Hallway, Outside door of room N124	Right of door of N124, left of exit sign above	200992-6	ATD	Radonova	11/30/2022	12/14/2023	0.5
3	NOSC Little Rock	2	Navy Operational Support Center	Hallway, Outside door of room N124	Right of door of N124, left of exit sign above	279494-9	ATD	Radonova	11/30/2022	12/14/2023	0.6
4	NOSC Little Rock	2	Navy Operational Support Center	Hallway, right of room N119	Right of room N119, by printer and board	555719-4	ATD	Radonova	11/30/2022	12/14/2023	0.5
5	NOSC Little Rock	2	Navy Operational Support Center	Hallway, right of room N119	Right of room N119, by printer and board	421747-7	ATD	Radonova	11/30/2022	12/14/2023	0.8
6	NOSC Little Rock	2	Navy Operational Support Center	N113	BTD	947270-5	ATD	Radonova	11/30/2022	12/14/2023	0.5
7	NOSC Little Rock	2	Navy Operational Support Center	N113	BTD	453322-0	ATD	Radonova	11/30/2022	12/14/2023	0.6
8	NOSC Little Rock	2	Navy Operational Support Center	N116	BTD	607965-1	ATD	Radonova	11/30/2022	12/14/2023	0.5
9	NOSC Little Rock	2	Navy Operational Support Center	N116	BTD	770842-3	ATD	Radonova	11/30/2022	12/14/2023	1.9
10	NOSC Little Rock	2	Navy Operational Support Center	N118A	Behind the door	121513-6	ATD	Radonova	11/30/2022	12/14/2023	0.6
11	NOSC Little Rock	2	Navy Operational Support Center	N118A	Behind the door	292325-8	ATD	Radonova	11/30/2022	12/14/2023	0.6
12		1	1 '								
13	Note :	1									
14	BTD = Behind the door										